



## SISTEMA DE GESTION DE LA CALIDAD

Comité Municipal de Agua Potable y Alcantarillado de Salamanca, Gto.

### 5. Lograr Eficiencia Energetica 0.67 KWH/m3

KWH DE POZOS 2022												
POZO	ENERO	FEBRERO	MARZO	ABRIL	MAYO	JUNIO	JULIO	AGOSTO	SEPTIEMBRE	OCTUBRE	NOVIEMBRE	DICIEMBRE
1	29,075	31,374	29,571	28,245	32,483	28,234	29,113	30,160	22,144	23,619	22,573	21,848
2	22,786	24,180	22,211	21,340	24,363	20,321	17,510	78	12,554	23,581	21,826	20,816
3	0	6,812	23	19	31	20	8	11,050	13,230	14,354	13,602	12,868
5	18,611	20,856	22,151	23,159	24,269	19,520	18,728	20,756	19,195	21,358	20,270	20,336
6	26,002	24,297	101	98	14,110	21,551	10,332	15,180	19,484	9,726	4,597	5,991
7	22,252	23,225	22,854	20,856	23,449	20,350	20,510	24,008	19,861	22,022	20,731	20,534
9	24,468	27,431	26,849	26,726	30,115	22,962	20,812	23,854	17,355	27,354	26,197	26,454
10 soto ines 2	27,360	36,960	24,960	32,240	32,880	28,880	31,440	10,160	6,960	80	1,440	34,000
11	51,360	44,400	48,880	44,560	49,440	43,240	43,240	52,240	43,040	46,160	47,280	43,760
12	21,191	22,253	21,454	20,489	23,389	19,651	20,393	22,211	20,249	21,194	19,651	16,053
13	28,560	33,840	36,320	35,600	37,200	28,880	36,960	43,760	13,120	34,880	37,760	28,640
14	43,465	24,370	43,698	41,721	46,061	42,073	43,510	47,914	42,020	45,986	42,637	41,669
15	12,310	13,094	8,494	8,082	9,159	7,941	8,564	9,943	8,728	9,564	8,672	8,763
17	20,800	22,800	21,680	21,440	23,840	20,880	22,880	32,560	24,880	24,080	23,760	23,600
18	26,644	28,333	23,454	24,860	27,532	23,573	23,725	26,114	23,301	25,921	23,742	23,740
19	56,640	60,160	55,680	53,680	62,080	53,360	56,080	61,200	53,040	59,200	53,040	800
20	30,945	33,261	30,955	29,956	33,495	28,058	27,713	25,888	27,387	30,000	27,889	26,834
21	6,262	5,672	5,532	3,427	5,708	4,971	5,072	5,416	4,891	5,542	5,327	5,474
22	4,418	5,162	4,764	7,453	6,924	4,370	5,008	6,198	6,418	5,645	4,530	4,753
23	5,096	5,753	5,323	7,188	7,311	6,697	7,670	8,037	7,289	7,720	6,751	7,958
24	42,240	37,600	43,920	46,160	47,440	46,880	49,200	40,560	42,320	42,748	41,976	38,960
25 VERGEL	1,292	1,468	2,217	1,372	1,466	1,149	1,126	1,273	1,150	1,091	1,188	1,224
25 PEMEX	39,360	41,280	39,280	39,520	42,160	34,720	34,880	37,840	34,400	39,360	36,640	35,680
26	123	3,246	26,300	25,045	19,993	16,951	11,556	16,788	184	103	134	5,087
27	27,483	33,962	31,453	25,611	34,716	29,062	29,494	29,945	16,749	24,723	23,044	26,472
28	21,862	23,586	21,579	21,152	24,017	20,957	21,860	24,725	22,078	23,772	22,575	21,978
29	21,090	22,431	20,793	20,035	22,706	19,440	20,930	22,756	20,011	21,905	20,425	20,101
30	11,431	13,344	13,216	12,561	14,438	12,689	13,010	14,695	13,125	14,639	13,048	13,114
31	14,599	19,440	18,933	17,831	20,145	17,426	18,147	20,063	16,203	16,044	14,332	14,513
32	15,016	16,047	15,050	14,162	9,657	123	7,017	2,896	10,935	15,648	13,881	13,398
33	4,601	4,082	5,269	4,049	4,314	4,166	4,664	5,152	4,348	4,429	4,396	3,952
34	8,880	8,800	16,240	19,200	22,960	16,480	15,600	6,480	24,160	30,480	29,040	18,720
35	25,079	24,006	26,259	24,867	27,478	25,124	24,137	27,162	24,943	26,035	27,947	27,053
36	4,373	4,680	4,505	5,387	5,718	4,412	4,304	4,791	4,010	4,753	4,517	4,052
37	10,805	11,708	10,034	10,990	10,984	8,439	8,357	9,233	8,351	9,241	8,633	8,834
41 ARBOLEDAS CIMATARIO	15,931	11,987	15,147	16,035	15,318	12,365	12,636	13,604	11,552	13,293	12,399	11,819
42 VILLA SALAMANCA 400	5,764	6,074	5,683	5,629	6,414	5,535	5,610	6,441	5,606	6,155	5,769	5,562
43 TOMASITAS	49,360	53,120	50,080	48,160	53,600	46,400	49,600	55,520	53,120	60,880	57,280	54,800
45 MARQUESA CD BAJIO	49	4,491	33	31	2,947	3,812	3,964	4,450	3,951	4,437	4,245	4,170



## SISTEMA DE GESTIÓN DE LA CALIDAD

Comité Municipal de Agua Potable y Alcantarillado de Salamanca, Gto.

### 5. Lograr Eficiencia Energética 0.67 KWH/m<sup>3</sup>

	ENERO	FEBRERO	MARZO	ABRIL	MAYO	JUNIO	JULIO	AGOSTO	SEPTIEMBRE	OCTUBRE	NOVIEMBRE	DICIEMBRE
SUMATORIA DE KWH	797,583	835,585	820,945	808,936	900,310	771,662	785,360	821,101	722,342	817,722	773,744	724,380
EXTRACCIÓN MENSUAL POZOS	1,239,951	1,118,335	1,225,754	1,208,415	1,253,658	1,190,015	1,190,019	1,162,051	1,100,701	1,174,846	1,165,595	1,183,459
ÍNDICE ENERGÉTICO 0.67 MAX	0.64	0.75	0.67	0.67	0.72	0.65	0.66	0.71	0.66	0.70	0.66	0.61