



SISTEMA DE GESTION DE LA CALIDAD

Comité Municipal de Agua Potable y Alcantarillado de Salamanca, Gto.

5. Lograr Eficiencia Energetica 0.67 KWH/m3

KWH DE POZOS 2023												
POZO	ENERO	FEBRERO	MARZO	ABRIL	MAYO	JUNIO	JULIO	AGOSTO	SEPTIEMBRE	OCTUBRE	NOVIEMBRE	DICIEMBRE
1	22,493	20,367	15,470	13,642	13,361	8,657	11,790	11,910	11,505	14,388	13,087	13,291
2	21,419	23,386	21,505	24,354	22,018	22,853	21,892	21,984	21,735	23,816	21,473	21,302
3	12,519	13,597	13,060	14,135	12,552	12,737	13,071	12,219	12,192	13,166	11,905	12,427
5	21,198	24,553	23,128	27,105	23,792	18,820	17,736	17,921	19,889	20,734	6,677	16,257
6	8,634	18,832	19,281	21,398	19,415	19,121	21,020	19,860	17,841	116	11,252	14,229
7	21,000	23,012	19,887	24,234	21,715	20,737	22,534	21,499	21,636	21,269	19,188	19,964
9	26,263	29,784	28,872	33,117	31,525	29,280	24,665	23,769	25,325	27,113	23,910	25,119
10 soto ines 2	16,960	14,160	44,400	19,200	80	15,120	14,080	15,680	3,120	1,440	19,680	15,680
11	44,000	47,200	42,960	45,600	49,600	42,320	39,600	48,560	45,680	48,640	44,240	44,000
12	17,219	19,322	18,446	21,271	20,410	19,566	18,859	18,679	18,305	19,569	18,555	18,198
13	27,840	30,640	26,880	35,440	39,120	34,000	34,240	19,920	23,760	35,920	31,840	14,160
14	41,471	45,819	41,647	47,248	41,341	41,408	44,571	43,023	41,865	45,548	41,459	41,333
15	8,734	9,563	9,156	10,960	10,508	9,766	10,640	9,979	9,954	10,459	8,933	9,227
17	25,280	29,760	26,000	29,600	26,400	23,040	0	0	19,040	24,320	22,640	22,800
18	23,155	24,290	22,478	25,617	24,579	23,729	22,629	22,382	20,994	21,949	19,696	20,292
19	29,440	38,880	80	35,440	22,560	80,720	54,880	53,040	50,720	57,040	53,200	50,720
20	27,057	29,480	26,838	30,514	27,600	28,926	27,911	28,022	28,135	30,103	27,171	27,366
21	7,661	12,736	5,532	20,704	9,217	9,648	7,771	7,736	3,998	238	6,607	7,115
22	2,487	88	1,693	4,597	11,415	12,758	12,737	12,321	12,818	13,759	12,765	12,165
23	7,366	8,610	7,683	8,687	7,841	8,169	7,990	7,949	7,910	8,382	7,555	7,477
24	39,760	36,160	40,160	38,118	41,246	38,960	36,320	39,040	41,138	30,303	33,600	15,760
25 VERGEL	1,243	1,469	1,302	1,705	1,436	1,253	1,425	1,334	1,352	1,489	1,249	1,329
25 PEMEX	37,680	46,880	36,000	46,560	43,360	42,000	39,680	41,440	42,960	46,720	42,960	44,400
26	9,079	15,171	14,462	18,450	26,615	18,198	18,791	18,394	15,379	18,221	11,670	22,250
27	21,186	22,865	25,777	27,828	26,280	26,092	30,253	27,025	27,672	25,270	17,759	19,936
28	21,903	23,627	21,646	17,421	1,210	18,965	19,517	19,516	20,015	21,113	19,367	19,247
29	19,950	21,713	19,667	22,358	19,777	20,795	20,054	19,981	20,153	20,376	20,582	19,504
30	10,818	11,451	11,956	5,024	87	3,039	2,160	3,386	5,010	5,255	4,412	4,482
31	15,645	18,166	16,954	16,321	109	103	5,703	14,958	15,061	16,477	15,049	19,100
32	12,812	15,257	14,565	10,072	13,259	15,344	14,658	14,015	14,392	16,063	13,702	13,195
33	3,681	3,912	4,104	4,228	4,457	3,681	3,633	3,769	3,690	4,005	3,453	3,641
34	23,680	29,120	26,560	30,080	26,400	24,320	24,960	25,920	11,040	20,640	16,000	6,000
35	28,207	24,777	23,129	24,526	27,710	25,134	25,948	29,916	28,655	29,059	26,284	26,917
36	4,067	5,232	4,399	4,862	5,273	5,019	4,643	4,689	4,390	4,594	4,103	4,390
37	9,259	10,556	10,240	11,997	12,126	11,180	10,172	10,915	11,101	12,447	10,286	10,461
41 ARBOLEDAS CIMATARIO	11,797	12,703	4,051	20,760	18,355	16,219	17,936	17,114	16,751	17,772	19,258	14,338
42 VILLA SALAMANCA 400	5,652	6,308	5,728	6,003	6,455	6,003	5,650	5,789	5,820	6,186	5,091	5,576
43 TOMASITAS	27,040	240	400	11,920	30,160	36,880	31,360	32,400	36,560	25,600	8,880	35,360
45 MARQUESA CD BAJIO	4,044	6,396	13,668	1,065	0	4,573	4,541	4,527	4,320	4,628	3,782	2,612



SISTEMA DE GESTIÓN DE LA CALIDAD

Comité Municipal de Agua Potable y Alcantarillado de Salamanca, Gto.

5. Lograr Eficiencia Energética 0.67 KWH/m3

	ENERO	FEBRERO	MARZO	ABRIL	MAYO	JUNIO	JULIO	AGOSTO	SEPTIEMBRE	OCTUBRE	NOVIEMBRE	DICIEMBRE
SUMATORIA DE KWH	719,699	776,082	709,764	812,161	739,364	799,133	746,020	750,581	741,881	764,187	699,320	701,620
EXTRACCIÓN MENSUAL POZOS	1,145,848	1,033,777	1,155,031	1,117,842	1,165,822	1,152,966	1,139,296	1,105,709	1,075,519	1,121,532	1,092,845	1,130,955
ÍNDICE ENERGÉTICO 0.67 MAX	0.63	0.75	0.61	0.73	0.63	0.69	0.65	0.68	0.69	0.68	0.64	0.62